

#15/1, Mallasandra, Off. Kanakapura Main Road, Bengaluru - 560 109 Phone: 080 2842 5012, 2842 5013, 2842 5163 | Fax: 080 -2842 5164

	RECEIPT	•	1.1 8
No. 5277		Date	.8/1/23
Received From Mr. / Miss	ivatea		
	studying in B.E/	MBA / M.Tech	
a sum of Rupees Three			
towards the Library fine / Xerox / S	Shortage of attendance / la	b. Breakage / Miscel	laneous
Cobe	Testing.	spl Scan	
			6
Rs. 300/			Accountant



Kammavari Sangham (R) 1952 K. S. GROUP OF INSTITUTIONS

K. S. SCHOOL OF ENGINEERING AND MANAGEMENT

Approved by AICTE, New Delhi; Affiliated to VTU, Belagavi, Karnataka; Accredited by NAAC www.kssem.edu.in

DEPARTMENT OF CIVIL ENGINEERING

DATE: 06/06/2023

To,

The Turnkey Homes

Bengaluru

1 set of 3 concrete cubes were sent for compressive strength test. The test was conducted for 10th day and results are described as below.

Date of testing: 05 June 2023

Cube no	Date of Casting	Weight (kg)	Max, load (kN)	Comp, Strength (N/mm²)	Avg, Strength (N/mm ²)	Remarks
1	26-05-2023	8.20	499.5	22.2		
2	26-05-2023	7.82	558.0	24.8	24.5	M30 grade
3	26-05-2023	7.95	598.3	26.5		J

Head of the Department Professor & Head

Dept. of Civil Engineering K.S. Group of Institutions K.S. School of Engineering & Management

Bangalore-560 062.



#15/1, Mallasandra, Off. Kanakapura Main Road, Bengaluru - 560 109 Phone: 080 2842 5012, 2842 5013, 2842 5163 | Fax: 080 -2842 5164

RECEIPT

No. 4925

Received From Mr. / Miss Kanthorall

y. Contille studying in B.E / MBA / M.Tech

a sum of Rupees Lendred Wife wo

towards the Library fine / Xerox / Shortage of attendance / lab. Breakage / Miscellaneous

Cube Leyh roy

Rs. 300

Accountant

Date: 1) 5 23

K.S.SCHOOL OF ENGINEERING &MANAGEMENT

#15 MALLASANDRA, OFF KANAKAPURA MAIN ROAD

Bangalore-560062

DEPARTMENT OF CIVIL ENGINEERING

To,

Date: 09-05-2023

V Consultants,

Bengaluru.

1 set of 3 concrete cubes were sent for compressive strength test. The test was conducted and results are described below.

Date of Testing: 09-05-2023

Cube	Weight	Max	Compressive	Avg.
No	(KG)	Load(Kn)	Strength(N/Mm²)	Strength(N/Mm²)
1	8.2	331.0	14.7	
2	8.0	402.4	17.8	14.5
3	8.35	259.3	11.5	

Faculty In charge

Head of the Department

\ulrelle

Professor & Head
Dept. of Civil Engineering
K.S. Group of Institutions
K.S. School of Engineering & Management
Bangalore-560 062.



#15/1, Mallasandra, Off. Kanakapura Main Road, Bengaluru - 560 109 Phone: 080 2842 5012, 2842 5013, 2842 5163 | Fax: 080 -2842 5164

No.	4276	RECEIPT	Date: 3/4/23
Rece	eived From Mr. / Miss	aghanondra	
••••••		studying in B.E / MB	
a sui	m of Rupees MYC	e pervolved of	epees only
towa		ox / Shortage of attendance / lab. E	Breakage / Miscellaneous
	Cer	be Testing	
0.			
Rs.	300/		Accountant

K.S.SCHOOL OF ENGINEERING &MANAGEMENT

#15 MALLASANDRA, OFF KANAKAPURA MAIN ROAD

Bangalore-560062

DEPARTMENT OF CIVIL ENGINEERING

To,

Date: 06-04-2023

V Consultants,

Bengaluru.

1 set of 2 concrete cubes were sent for compressive strength test. The test was conducted and results are described below.

Date of Testing: 03-04-2023

Cube No	Weight	Max Load(Kn)	Compressive Strength(N/Mm²)	Avg. Strength(N/Mm²)
1	8.20	452.1	20.0	
2	8.10	409.3	18.1	19.00

Taculty In-charge

Head of the Department

Witcelle

Professor & Head Dept. of Civil Engineering K.S. Group of Institutions M.S. School of Engineering & Management Bangalore-560 062.



#15/1, Mallasandra, Off. Kanakapura Main Road, Bengaluru - 560 109 Phone: 080 2842 5012, 2842 5013, 2842 5163 | Fax: 080 -2842 5164

λT_{α}

No.

4218

RECEIPT

Date : .3.1.3/

Received From Mr. / Miss Many Many
a sum of Rupees ove thousand suffer on
towards the Library fine / Xerox / Shortage of attendance / lab. Breakage / Miscellaneous
towards the Library fine / Xerox / Shortage of attendance / lab. Breakage / Miscellaneous

Rs.