

main block - 4th floor South side corner - 25 kVA ORIGINAL

TIN : 29680097511  
 CST : 01558705 } Dt. 18-07-94

**TAX INVOICE**



30 5/11/11

To. K.S.SCHOOL OF ENGINEERING & MANEGEMENT  
 15, RAGHUVANAHALLI,  
 KANAKAPURA ROAD,  
 BANGALORE - 62

**SATELLITE ELECTRONICS**

Mfs : UPS, INVERTORS, POWER SUPPLIES

No. 1048, Sakamma Hanumanthappa Layout,  
 Kavalbyrasandra, R. T. Nagar,  
 Bangalore - 560 032.  
 Telefax : 23338768, 23430372

Party's TIN : KSGI/PO/2011-12/178

Bill No.: 00019

P.O. No.: \_\_\_\_\_ Date \_\_\_\_\_

Date 10/6/2011

Time of Removal 10:00:00 AM

SI.No.	DESCRIPTION	QUANTITY	RATE/UNIT	AMOUNT Rs. Ps.
1	POWERLINE MAKE 25KVA ONLINE UPS WITH EXIDE MAKE 6EL40+ BATTERIES FOR HALF HOUR BACKUP & BATTERY STAND.	1	266,667.00	266,667.00
	VAT @ 5%			13,333.35
				<b>280,000.35</b>



*[Signature]*  
 20/7/2011  
 Principal / Director  
 K.S. Group of Institutions  
 Bangalore - 560 062.


RUPEES IN WORDS  
**TWO LACK EIGHTY THAUSAND ONLY**

Interest at 21% will be charged if the bill is out paid within Seven (7) days

For SATELLITE ELECTRONICS

*[Signature]*

E & O.E.







Kammavari Sangham (R) 1952  
K.S. Group of Institutions

**K.S. SCHOOL OF ENGINEERING. & MANAGEMENT**

(Approved by AICTE & Affiliated to VTU)

No. 15, Mallasandra, off. Kanakapura Road, Bangalore - 560 062

Ph : 080 - 28425012, 28425013, 28425163. Mob. : 9738553379 Fax : 080 - 28425164

PURCHASE ORDER

Ref : KSGI/PO/2011-12/176

Date : 24/05/2011

To,  
SATELLITE ELECTRONICS  
No. 1048, S.H. Layout, Kavalbyrasandra,  
R.T Nagar,  
Bangalore - 560 032.

Dear Sir,

Sub: Supply of Power Line Make 25 KVA Online UPS System.

Ref: SE/11/ 026, Date : 12-05-2011

With reference to the above, we are pleased to place order for supply of Power Line Make 25 KVA Online UPS System with Half Hour Backup at K.S.G.I, #15, Mallasandra, off Kanakapura Road, Bangalore -62 as per the following specifications, terms & conditions.

Sl No	Particulars	Qty	Unit Price in Rs	Total Price Inclusive of all Taxes in Rs
1	POWERLINE MAKE 25 KVA ONLINE UPS HALF HOUR BACKUP TIME TECHNOLOGY: HIGH FREQUENCY IGBT BASED, INPUT PF: > 0.90, IGBT CHARGER, LCD DISPLAY, DC VOLTAGE: 360 VDC , INPUT : 3 PHASE, OUT PUT : 1, PHASE, AC 230V.	01	2,80,000	2,80,000.00
2	EXIDE MAKE 6 EL 40+, 40 AH TUBULAR BATTERY FOR 45 - 60 MINUTES WITH BATTERY RACK AND INCONNECTING CABLES. ( WARRANTY - UPS - 2 YEARS, BATTERIES - 5 YEARS )	30		
GRAND TOTAL AMOUNT INCLUSIVE OF ALL TAXES (IN RS.)				2,80,000.00

*[Signature]* Contd.. Page 2

Accepted according to the purchase  
order & received original on  
date of 26/05/2011.  
(MR. TARAKESH)

*[Signature]*  
25/5/2011  
Principal / Director  
K.S. Group of Institutions  
Bangalore - 560 062.





Kammavari Sangham (R) 1952  
K.S. Group of Institutions

# K.S. SCHOOL OF ENGINEERING. & MANAGEMENT

(Approved by AICTE & Affiliated to VTU)

No. 15, Mallasandra, off. Kanakapura Road, Bangalore - 560 062


Ph : 080 - 28425012, 28425013, 28425163. Mob. : 9738553379 Fax : 080 - 28425164

Page 2


## Terms & Conditions

1. Delivery: 1 to 2 Weeks from the date of Confirmed PO.
2. Payment: After Delivery & installation.
3. Warranty: 2 years onsite warranty for UPS system & 5 years onsite warranty for Exide Make 6EL 40+ Batteries.
4. Service : Battery & UPS Condition Should Check & Service Twice in a Semester.
5. All the components in the Power Line Make 25 KVA Online UPS System & Exide Batteries supplied by you must be as specified by SATELLITE ELECTRONICS, failing which the entire lot will be rejected and the penalty will be levied. The penalty will be the bank interest on the total order cost for the period of one month.

Thanking you,


  
25/5


Secretary  
Kammavari Sangham  
Bangalore

  
25/5/2011  
Principal / Director  
K.S. Group of Institutions  
Bangalore - 560 062.

Accepted according to the purchase order & received original on date of 26/05/2011.

Received Advance cheque  
Amount 1,50,000/- on date  
of 26/05/2011.

  
26/05  
(TARAKESH).

  
(MR. TARAKESH) 26/05  
SATELLITE ELECTRONICS  
91646 22348.




# VASANTHA ENTERPRISES

# 4289/2, 21st Main, Subramanyanagar, Bangalore - 560 021. Ph : 9844723743

## SERVICE REPORT

Installation  Warranty  Chargeable Call  PMC  AMC

Customers Name & Address : K.S.S. E M Kanakapura Road B'Coop		No. 019 Date : 2/12/14		
		Time : 1.00 PM		
UPS Rating : 25KVA I/P Voltages : 415V		O/P Voltages : 218V		
System Serial No :		Inverter O/P :		
Battery Voltages :	No. 1 :	No. 2 :	No. 3 :	No. 4 : 397V
Battery Rating : 40 AH		Distilled Water Level : Normal		
Charging Current : 4 Amps		Charging Voltages : 405V		
Load Connected : Yes.				
Problem Reported : UPS is not working				
Service Carried Out : Found that failure of DC capacitor, hence done CWD, 2HBTs Replaced the both now the UPS is working normally with load				
Components Replaced : Capacitor - ① nos. 2HBT - ② nos hate drive card - ① nos				
Customers Seal & Signature Rajesh 02/12/14		Call Completion Date : 2/12/14 Time : 3.45 PM		Service Engineer Name & Signature 





# SATELLITE ELECTRONICS

No. 1048, S.H. Layout, Kavalbyrasandra,  
R.T. Nagar, Bangalore - 560 032  
Tel fax : 23338768, 23430372



AN ISO 9001-2000 CERTIFIED COMPANY

## TAX INVOICE

TIN: 29680097511  
ST NO: ABEPR 3776 M ST001

<b>CONSIGHNEE :</b>		<b>PARTY'S TIN:</b>	<b>INVOICE NO: 007</b>	
<b>THE PRINCIPAL, M/S. K.S.SCHOOL OF ENGG &amp; MANAGEMENT, KANAKAPURA ROAD BANGALORE -</b>			<b>DATE : 07/05/14</b>	
		<b>P.O.NO:</b>	<b>TIME 2.10 PM</b>	

SL NO	ITEM DESCRIPTION	QTY	RATE/UNIT	AMOUNT
	<b>SERVICE AND REPAIR OF 30 KVA ONLINE UPS.</b>			
1	REPLACEMENT OF INVERTER SECTION IGBT & RELATED COMPONENTS	2,700.00	2	5,400.00
2	RETUNING OF INVERTER PCB & SERVICE	1,050.00	1	1,050.00
	VAT @ 5.5%			354.75
				6,450.00
	SERVICE CHARGES	1,500.00	1	1,500.00
	ST @ 12.36%			185
	<b>TOTAL</b>			<b>8490</b>

*[Signature]*  
13/5/14  
Principal / Director  
K.S. School of Engineering & Management  
Bangalore - 560 062

RUPEES IN FIGURES  
K S SCHOOL OF ENGINEERING & MANAGEMENT  
Bangalore - 560 062  
THOUSAND FOUR HUNDRED NINETY ONLY

REMARKS

DECLARATION:  
WE DECLARE THAT THIS INVOICE SHOWS THE ACTUAL PRICES OF THE GOODS DESCRIBED AND THAT ALL PARTICULARS ARE THERE AND CORRECT

*[Signature]* 13/5/14  
For SATELLITE ELECTRONICS  
*[Signature]*



# VASANTHA ENTERPRISES

# 4289/2, 21st Main, Subramanyanagar, Bangalore - 560 021. Ph : 9844723743

## SERVICE REPORT

Installation  Warranty  Chargeable Call  PMC  AMC

Customers Name & Address : K.S.S E M Kanakapura Road B'lore		No. 018 Date: 1/12/17	
UPS Rating : 25kVA I/P Voltages : 415V		Time: 4:00 PM O/P Voltages : -	
System Serial No :		Inverter O/P : 218V	
Battery Voltages : 407V	No. 1 :	No. 2 :	No. 3 :
Battery Roting : 60 AH		Distilled Water Level : normal	
Charging Current : 4 A		Charging Voltages : 204V	
Load Connected : Yes			
Problem Reported : UPS not working			
Service Carried Out : Found that Battery of ELB 5 4 mode drive card & Capacitors Estimation = Elb 5 = 2850 x 2 = 5700 Cathode card 150 x 1 = 650 Capacitor 2250 x 4 = 9000 Screw size = 1500			
Components Replaced :			
Customers Seal & Signature Rajesh 1/12/2017		Call Completion Date: 1/12/17 Time: 8:20 PM	22700 4086 26786 Service Engineer Name & Signature



## INVIOCE

**VASANTHA ENTERPRISES**  
 No.4289/2, 21ST MAIN ROAD  
 SUBRAMANYANAGAR  
 BANGALORE- 560021  
 9844723743  
 GSTIN:29ARJPV7492B1Z6

Bill no: 023	Date 02.12.2017
Delivery Note	Mode/Term of Payment
Supplier's Ref	Date
Buyers Order No	Date
Dispatch Document No	Destination
Terms of Delivery	

**K S S E M (Main Block 4th Floor South Side)**  
 KANAKAPURA ROAD  
 BANGALORE-560109


Diserption of Goods	Qty	Rate	Amount
SERVICING OF 25 KVA UPS POWER LINE MAKE REPLACING OF GATE DRIVE CARD AND REPLACING OF CAPACITORS AND REPLACING OF IGBT,S IN INVERTER SECTION	1	22,700.00	22,700.00
SGST@9%			2,043.00
CGST,@9%			2,043.00
Net Amount to be Received			26,786.00

Amount Chargeable(in words)  
 TWENTY SIX THOUSAND SEVEN HUNDRED & EIGHTYSIX ONLY

E & O.E

We declare that this invoice shows the actual price of the goods described and that all particulars are true and correct

For VASANTHA ENTERPRISES



*Signature*  
4/12/17

**Dr. S. N. SRIDHARA**  
 Principal/Director  
 K. S. School Of Engineering & Management  
 BENGALURU:-560 109.



CASH BILL

Ph.: 9844844917

# SREE VINAYAKA ELECTRONIC


# 4289/2, 1st Main Road, Subramanyanagar, Bangalore - 21.

To The Principal K.S.S.E.M  
B'lore

No. 307

Date: 17/05/17

Sl. No.	PARTICULARS	QTY.	RATE	AMOUNT
	Servicing of 25 KVA UPS. Replaced the Component <u>INVT</u>	01	3750.	3750.
	Control card } Components } dated. 13/05/17.	02	450	650.
		01	550	550.
	Fan	01	750	750.
	Service charge			750
	Six Thousand Two			
			TOTAL	6250/



17/05/17 For SREE VINAYAKA ELECTRONIC

*[Signature]*

K.S.S.E.M School Of Engineering



# SREE VINAYAKA ELECTRONIC

# 4289/2, 21st Main, Subramanyanagar, Bangalore - 560 021. Ph : 9844723743

## SERVICE REPORT

Installation  Warranty  Chargeable Call  PMC  AMC

Customers Name & Address :

K S S E M Mallanahalli  
B'lore - 560009

No. 001 Date : 13/05/12

Time : 6:30 am.

UPS Rating : 2SKVA I/P Voltages : 399V

O/P Voltages : 230V

System Serial No :

Inverter O/P : 230V

Battery Voltages :

No. 1 : 400

No. 2 : 402

No. 3 : 403

No. 4 : 406

Battery Rating : 60 AH

Distilled Water Level : Medium

Charging Current : 6 Amps

Charging Voltages : 406 V

Load Connected : Yes

Problem Reported :

UPS Restart issue

Service Carried Out :

Found that failure of IGBT is in control card components, and also found that fans also not working. Replaced the IGBTs & replaced the components in control card.

Components Replaced :

IGBT - 01 Control card components


Customers Seal & Signature

13/5/12  
Dr. S. N. SRIDHARA  
Principal/Director  
K. S. School Of Engineering & Management  
BANGALORE - 560 109.

Call Completion

Date : 13/05/12

Time : 7:30am

  
Service Engineer  
Name & Signature